

Section 07218
K-13 Spray-On Systems
Specification Guide 0697

PART 1 - GENERAL

1.01 Work Included:

- A. The work to be performed under this section shall include all materials, equipment, labor and services required to install the sprayed cellulose fiber in accordance with these specifications and as indicated on the drawings if applicable.
- B. A representative surface of not less than 100 square feet shall be sprayed and approved by the Architect and/or Owner prior to proceeding.

1.02 Related Work:

- A. Clips, hangers, supports, sleeves and other attachments to spray bases are to be placed by other trades prior to the application of sprayed insulation.
- B. Ducts, piping, conduit or other suspended equipment shall not be positioned until after the application of sprayed insulation.

1.03 Systems Description/Quality Assurance:

- A. Contractor must use a total system, encompassing equipment, fiber and adhesive as supplied and tested by the manufacturer. No substitution may be made.
- B. Fibers supplied under this specification shall have each bag coded with the date and lot number of manufacture, and retained samples shall be kept by the manufacturer for not less than one year.
- C. Contractor must be licensed and trained by the manufacturer.

1.04 Submittals:

- A. Submit product data and manufacturer's certificate that the product meets or exceeds specified requirements.
- B. Manufacturer's written certification that product contains no asbestos, fiberglass or other man made mineral fibers.

1.05 Product Delivery, Storage and Handling:

- A. Materials shall be delivered in original, unopened containers bearing name of manufacturer, product identification and reference to U.L. testing.
- B. Store materials off ground, under cover and away from damp surfaces and keep material dry at all times.
- C. Protect liquid adhesive from freezing.

8. Non corrosive per UMB-80.
9. Bond Deflection per ASTM E-759.
6" Deflection in 10' Span – No Spalling or Delamination
10. Cohesive Strength at time of application per Method WS-2000: > 700 Grams

PART 3 - EXECUTION

3.01 Inspection-Preparation-Installation:

- A. The installing contractor shall examine all surfaces and report all unsatisfactory conditions in writing to the General Contractor and Architect. The work shall not proceed until unsatisfactory conditions are corrected.
- B. Provide masking, drop cloths or other satisfactory coverings for all materials/surfaces which are not to receive insulation to prevent damage from over-spray.
- C. Surfaces to receive spray insulation shall be inspected prior to application to determine if priming/sealing is required to insure bonding and/or to prevent discoloration caused by migratory stains. Prime accordingly.
- D. Thickness will be determined as the minimum thickness measured as per ASTM E-605 field test procedure.
- E. The work shall be coordinated with other trades whose work may be affected or have an effect on the installation of the sprayed cellulose fiber.
- F. Installation, clean up and curing shall be accomplished according to the manufacturer's recommendations and common construction standards.
- G. Provide natural or mechanical ventilation continuously to properly cure the insulation.

3.02 Protection:

- A. Protect finished installation under provision of section 01500 and 01535.

3.03 Schedule:

- A. K-13 Spray-on Systems color and thickness to be determined.