

PART 2 - PRODUCTS

2.01 Acceptable Manufacturers:

- A. International Cellulose Corporation
12315 Robin Boulevard
Houston, Texas 77045
(713) 433-6701 or (800) 444-1252
FAX: (713) 433-2029

2.02 Materials:

- A. SonaSpray "FC" Acoustical Treatment

PART 3 - EXECUTION

3.01 Inspection-Preparation-Installation:

- A. The acoustical contractor shall examine all surfaces and report all unsatisfactory conditions in writing to the General Contractor and Architect. The work shall not proceed until unsatisfactory conditions are corrected.
- B. Provide masking, drop cloths or other satisfactory coverings for all materials/surfaces which are not to receive insulation so as to prevent damage from over-spray.
- C. Surfaces to receive spray insulation shall be inspected prior to application to determine if priming/sealing is required to insure bonding and/or to prevent discoloration caused by migratory stains. Prime accordingly.
- D. The work shall be coordinated with other trades whose work may be affected or have an effect on the installation.
- E. Installation, clean-up and curing shall be accomplished according to the manufacturer's recommendations and common construction standards.
- F. The sprayed acoustical material shall be applied to an average thickness of 1/2" to achieve an NRC of .65 or greater.
- G. Provide natural or mechanical ventilation continuously to properly cure the insulation.